Quality On Tap!
WAGONER COUNTY RURAL WATER DISTRICT #7
P.O. BOX 67 OKAY, OK 74446 (918) 683-4737 WWW.RWD7.RURALWATERUSA.COM

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Wagoner Co. RWD #7 Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes. The standard or MCL for total trihalomethanes is 0.080 mg/l. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's locations was the following:

Monitoring Location	*Twelve-month time period*	*Locational RAA*
DBPMX – LR McGlothlin, 10605 N 28th St E Wagoner	*Third Quarter 2026*	*0.089 mg/L*
TTHM_01_5342 N 55th St, East Fort Gibson	*Third Quarter 2026*	*0.087 mg/L*

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

CORRECTIVE ACTION

What happened? What is being done? When will the violation be resolved?

Local volunteer fire department flushed lines before our tests. Corrective actions: The issue should now be resolved.

For further information contact: Brian Hathaway, Plant Manager - (918-869-7429)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Wagoner Co. RWD #7 PWSID#: OK1221626

Date Distributed: 11-16-2026